



<b>(A) GENERAL SITE/BUILDING INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
A.01	Urban Features	Bicycle Infrastructure	P.01.1-4
A.02	Receptionist	N/A	
A.03	Qualified Singer / Languages Spoken	N/A	
A.04	Site Access	Vehicle/ Wheelchair/ TG	
A.05	Parking Area Access	N/A	
A.06	Drop Off Point	N/A	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	INA	P.03.1-2
A.08	Onsite Wheelchair-Accessible Vehicle Parking	INA	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	INA	P.05
A.10	Access Ramps	INA	P.06
A.11	Lifting Platforms	N/A	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	N/A	P.08
A.13	Disabled Elevators	N/A	
A.14	Tactile Site/Building Guidance	INA	
A.15	Braille Writing System Signage/Tactile Diagrams	N/A	
A.16	Hearing/Speech Impaired Communication Syst.	N/A	
A.17	Emergency Alerting Systems	N/A	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area /on street	INA	P.10
A.20	Surface Materials – General Paved Area	Colored Asphalt	P.01.1-4
A.21	Surface Materials – Seating Area	N/A	P.12
A.22	Surface Materials – Water Fountain Area	No	P.13
A.23	Surface Materials – Bar-B-Que Area	N/A	P.14
A.24	Surface Materials – Playground Area	N/A	P.15
A.25	Drain Covers Types	Yes (See Photos)	P.16
A.26	Indoor Light Intensity(LUX)	N/A	
A.27	Outdoor Light Intensity (LUX)	INA	



<b>(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
B.01	Special Category Type Site/Building	Urban Refurbishment/ Infrastructure	
B.02	Ticket Counter Height/Knee Space	N/A	P.17
B.03	Ticket Counter Area (r ≥1.50m) or	N/A	P.17
B.04	Inclusive Furnishings	INA	P.18
B.05	Inclusive Furnishings Location	INA	
B.06	Disabled Friendly Water Fountains	INA	P.13
B.07	Disabled Friendly Bar-B-Que	N/A	P.14
B.08	Playground Area Disabled Access	N/A	P.15
B.09	Special Needs Playground Equipment	N/A	P.19
B.10	Trash Receptacles Area Access	INA	P.20
B.11	Disabled Friendly Trash Receptacles	INA	P.21
B.12	Recycle Receptacles Area Access	INA	P.22
B.13	Disabled Friendly Recycled Receptacles	INA	P.23
B.14	Urban Area Signage	INA	P.24
B.15	Other: According to the municipality officials, the Bicycle Path network is under study and partial construction. At traffic lights, the bicycle path can be used by disables. Also, the municipality program provides for a plan for buying disabled electric bicycles.	Yes	P.01.1-4 (as given by the municipality)



<b>(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	General Picnic Area	P.06.1
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	10% - 18.0m x 2.00m	
D.08	Inclined Plane Handrails	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

<b>(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.4-6
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 <sup>st</sup> Inclined Plane (Slope-Length x Width)	5%-10.0m x 1.20m	
D.08	1 <sup>st</sup> Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 <sup>st</sup> Inclined PlnHandrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 <sup>st</sup> Inclined Plane - Width between Handrails	1.00m	
D.11	1 <sup>st</sup> Inclined Plane Edge Protection	Yes	
D.12	1 <sup>st</sup> intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 <sup>st</sup> Landing Handrails information	Both Sides/One Side/No	
D.14	1 <sup>st</sup> Landing Edge Protection	Yes	
D.15	2 <sup>nd</sup> Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 <sup>nd</sup> Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 <sup>nd</sup> Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 <sup>nd</sup> Inclined Plane - Width between Handrails	1.00m	
D.19	2 <sup>nd</sup> Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	



<b>(D) ACCESS RAMPS DETAILS – RAMP #04 (&lt;5%)</b>			
<b>ITEM#</b>	<b>PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
D.01	Access Ramp Location	General Picnic Area	P.06.6-7
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	N/A	
D.06	Bottom Landing Dimensions (Length x Width)	N/A	
D.06	Inclined Plane (Slope-Length x Width)	2% -20% - Varies	



<b>(E) SIGNAGE INFORMATION</b>			
<b>ITEM#</b>	<b>AREA – SIGNAGE PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
E.01	Site/Building – Address Number	INA	
E.02	Site/Building – Site/Building Name	INA	P.01
E.03	Parking – Disabled Parking Space Symbol	INA	
E.04	Parking – International Accessibility Symbol	INA	
E.05	Parking – Building Access Ramp Location	INA	
E.06	Parking – Site Diagram	INA	
E.07	Parking – Directional	INA	
E.08	Parking – General Information	INA	
E.09	Entrance/Reception – Site/Building Diagram	INA	
E.10	Entrance/Reception – Directional	INA	
E.11	Entrance/Reception – Bathroom Location	INA	
E.12	Entrance/Reception – General Information	INA	
E.13	Inside Facility – Exhibition Area Labels	INA	P.25
E.14	Inside Facility – Site/Building Diagram	INA	
E.15	Inside Facility – Directional	INA	
E.16	Inside Facility – Bathroom Location	INA	
E.17	Inside Facility – Emergency Exit	INA	
E.18	Facility’s Outdoor Area – Site/Building Diagram	INA	
E.19	Facility’s Outdoor Area – Directional	INA	
E.20	Other (Description)	INA	

<b>(F) HEARING &amp; SPEECH IMPAIRED INFORMATION</b>			
<b>ITEM#</b>	<b>AREA – PROVISION DESCRIPTION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
F.01	Qualified Signer	N/A	
F.02	Sign Languages Spoken	N/A	
F.03	Reception Design Specific Space	N/A	
F.04	Visual Emergency Alerting Systems	N/A	
F.05	Augmenting Systems – ex. Induction Loop	N/A	
F.06	Augmenting Systems –ex. Fm	N/A	
F.07	Transforming Systems – ex. Captioned Phone	N/A	
F.08	Transparent Masks for Covid-19	N/A	



**(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE**

<b>ITEM#</b>	<b>TACTILE PROVISION (FROM – TO)</b>	<b>CHECKLIST</b>	<b>PHO#</b>
G.01	Public Sidewalk to Parking Area	INA	
G.02	Public Sidewalk to Entrance	INA	
G.03	Parking Area to Public Building Entrance	N/A	
G.04	Reception to Bathrooms	N/A	
G.05	Reception to other Interior Areas	N/A	
G.06	Interior Areas to Emergency Exit	N/A	
G.07	Interior Areas to Outdoor Spaces	N/A	

**(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAMS**

<b>ITEM#</b>	<b>BRAILLE &amp; TACTILE DIAGRAM PROVISION</b>	<b>CHECKLIST</b>	<b>PHO#</b>
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	N/A	
H.07	Room Info & Number Location in Braille	No	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



<b>LEGEND</b>		
<b>ITEM#</b>	<b>ABBREVIATION</b>	<b>MEANING</b>
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 <sup>st</sup>	1 <sup>st</sup> Floor
14	2 <sup>nd</sup>	2 <sup>nd</sup> Floor
15	MF	Mezzanine Floor