



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Plateaus & Sloped Areas	P.01.1-9
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	Yes	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	No	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	2- Yes (2.70m x 5.00m)	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-18
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(2.00x1.70m)/ ≥90cm	P.08.1-2
A.13	Disabled Elevators	N/A	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	Concrete	P.10
A.20	Surface Materials – General Picnic Area	Earth	P.11
A.21	Surface Materials – Seating Area	Earth/Stone/Concrete Paving	P.12
A.22	Surface Materials – Water Fountain Area	Stone (More info in part B)	P.13
A.23	Surface Materials – Bar-B-Que Area	Stone (More info in part B)	P.14.1-3
A.24	Surface Materials – Playground Area	Rubber (More in part B)	P.15
A.25	Drain Covers Types	No	P.16
A.26	Indoor Light Intensity (LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Natural Site/ Picnic area	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	P.17
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	Yes/ Difficult Access	P.18.1-2
B.05	Inclusive Furnishings Location	Near Entrance	
B.06	Disabled Friendly Water Fountains	No	P.13
B.07	Disabled Friendly Bar-B-Que	No	P.14
B.08	Playground Area Disabled Access	Difficult Access / Step	P.15
B.09	Special Needs Playground Equipment	No	P.19
B.10	Trash Receptacles Area Access	Accessible	P.20.1-2
B.11	Disabled Friendly Trash Receptacles	No	P.21
B.12	Recycle Receptacles Area Access	Not Available	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Picnic Area Signage	Yes	P.24.1-4
B.15	Canteen Counter Height	N/A	P.25
B.16.1	Other: The forestry department recently completed some concrete constructions, considered for WCA BBQ	Yes	P.14.2-3



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	WCA Bathroom	P.06.1-3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	15%- 0.80m x 1.70m	
D.08	1 st Inclined Plane Handrails information	Yes	
D.09	1 st Inclined Plane Handrails Height (70cm&90cm)	90cm	
D.10	1 st Inclined Plane - Width between Handrails	N/A	
D.11	1 st Inclined Plane Edge Protection	No	
D.12	1 st intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.13	1 st Landing Handrails information	One Side	
D.14	1 st Landing Edge Protection	No	
D.15	2 nd Inclined Plane (Slope-Length x Width)	10% - 0.90m x 1.40m	
D.16	2 nd Inclined Plane Handrails information	One Side	
D.17	2 nd Inclined Pln Handrails Height (70cm &90cm)	90cm	
D.18	2 nd Inclined Plane - Width between Handrails	N/A	
D.19	2 nd Inclined Plane Edge Protection	No	
D.20	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Picnic Area Bathrooms	P.06.4-5
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	19%- 0.50m x 1.60m	
D.08	1 st Inclined Plane Handrails information	No	
D.09	1 st Inclined Plane Handrails Height (70cm&90cm)	N/A	
D.10	1 st Inclined Plane - Width between Handrails	N/A	
D.11	1 st Inclined Plane Edge Protection	No	
D.12	1 st intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.13	1 st Landing Handrails information	No	
D.14	1 st Landing Edge Protection	No	
D.15	2 nd Inclined Plane (Slope-Length x Width)	19% - 2.70m x 1.40m	
D.16	2 nd Inclined Plane Handrails information	One Side	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	80cm	



D.18	2 nd Inclined Plane - Width between Handrails	1.20m	
D.19	2 nd Inclined Plane Edge Protection	No	
D.20	Bottom Landing Dimensions (Length x Width)	1.40m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	

(C) ACCESS RAMPS DETAILS – RAMP #03 (≥5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Disabled Trail	P.06. 6-16
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	9%- 10.00m x 1.50m	
D.08	1 st Inclined Plane Handrails information	One Side	
D.09	1 st Inclined Plane Handrails Height (70cm&90cm)	60cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	N/A	
D.11	1 st Inclined Plane Edge Protection	No	
D.12	1 st intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.13	1 st Landing Handrails information	One Side	
D.14	1 st Landing Edge Protection	No	
D.15	2 nd Inclined Plane (Slope-Length x Width)	9%- 18.00m x 2.00m	
D.16	2 nd Inclined Plane Handrails information	One Side	
D.17	2 nd Inclined Plane Handrails Height	60cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	N/A	
D.19	2 nd Inclined Plane Edge Protection	No	
D.20	2 nd intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.21	2 nd Landing Handrails information	One Side	
D.22	2 nd Landing Edge Protection	No	
D.23	3 rd Inclined Plane (Slope-Length x Width)	11%- 4.00m x 2.00m	
D.24	3 rd Inclined Plane Handrails information	One Side	
D.25	3 rd Inclined Plane Handrails Height	60cm & 90cm	
D.26	3 rd Inclined Plane - Width between Handrails	N/A	
D.27	3 rd Inclined Plane Edge Protection	No	
D.28	3 rd intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.29	3 rd Landing Handrails information	One Side	
D.30	3 rd Landing Edge Protection	No	
D.31	4 th Inclined Plane (Slope-Length x Width)	7%- 8.10m x 1.50m	
D.32	4 th Inclined Plane Handrails information	One Side	
D.33	4 th Inclined Plane Handrails Height	60cm & 90cm	
D.34	4 th Inclined Plane - Width between Handrails	N/A	
D.35	4 th Inclined Plane Edge Protection	No	



Mandra tou Kambiou Picnic Area, Nicosia

NIC 066

D.36	4 th intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.37	4 th Landing Handrails information	One Side	
D.38	4 th Landing Edge Protection	No	
D.39	5 th Inclined Plane (Slope-Length x Width)	Various %- 50m x 1.20m	
D.30	5 th Inclined Plane Handrails information	One Side	
D.41	5 th Inclined Plane Handrails Height	60cm & 90cm	
D.42	5 th Inclined Plane - Width between Handrails	N/A	
D.43	5 th Inclined Plane Edge Protection	Yes	
D.44	5 th intermediate Level Landing (Length x Width)	≥1.50m x 1.20m	
D.45	5 th Landing Handrails information	One Side	
D.46	5 th Landing Edge Protection	No	
D.47	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.47	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #04 (<5%)

ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance to General Picnic Area	P.06.17-18
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	N/A	
D.06	Bottom Landing Dimensions (Length x Width)	N/A	
D.06	Inclined Plane (Slope-Length x Width)	2% -2.50m x 2.30m	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 st	1 st Floor
14	2 nd	2 nd Floor
15	MF	Mezzanine Floor