



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Natural Features	Plateaus & Sloped Areas	P.01.1-4
A.02	Receptionist	No	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle	
A.05	Parking Area Access	Free	
A.06	Drop Off Point	N/A	P.02
A.07	Onsite Disabled Parking Spaces (3.30x5.00m)	N/A	P.03
A.08	Onsite Wheelchair-Accessible Vehicle Parking	N/A	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms-Dimensions/ Door width	1-(1.90x1.60m)/0.77cm	P.08
A.13	Disabled Elevators	No (More info in part C)	P.09
A.14	Tactile Site/Building Guidance	No (More info in part G)	
A.15	Braille Writing System Signage/Tactile Diagrams	No (More info in part H)	
A.16	Hearing/Speech Impaired Communication Syst.	No (More info in part F)	
A.17	Emergency Alerting Systems	No (Audible & Visual)	
A.18	Staircase Disabled Emergency Waiting Point	N/A	
A.19	Surface Materials – Parking Area	Soil	P.10
A.20	Surface Materials – General Picnic Area	Soil/Stone Pavings	P.11.1-2
A.21	Surface Materials – Seating Area	Soil/Grass/Concrete	P.12.1-2
A.22	Surface Materials – Water Fountain Area	N/A	P.13
A.23	Surface Materials – Bar-B-Que Area	Concrete	P.14
A.24	Surface Materials – Playground Area	N/A	P.15
A.25	Drain Covers Types	N/A	P.16
A.26	Indoor Light Intensity(LUX)	INA	
A.27	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Site/Building	Natural Site	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	N/A	
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	P.17
B.04	Inclusive Furnishings	Yes/Not Accessible	P.18
B.05	Inclusive Furnishings Location	Close to Parking Entrance	
B.06	Disabled Friendly Water Fountains	No	P.13
B.07	Disabled Friendly Bar-B-Que	No	P.14
B.08	Playground Area Disabled Access	N/A	P.15
B.09	Special Needs Playground Equipment	N/A	P.19
B.10	Trash Receptacles Area Access	Accessible/ Difficult Access	P.20
B.11	Disabled Friendly Trash Receptacles	No	P.21
B.12	Recycle Receptacles Area Access	N/A	P.22
B.13	Disabled Friendly Recycled Receptacles	No	P.23
B.14	Picnic Area Signage	Partial	P.24.1-2
B.15	Canteen Counter Height	N/A	P.25



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	WC Entrance	P.06
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	13% - 2.00m x 1.20m	
D.08	Inclined Plane Handrails	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

(D) ACCESS RAMPS DETAILS – RAMP #04 (<5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	WC Entrance	P.06.2
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	N/A	
D.06	Bottom Landing Dimensions (Length x Width)	N/A	
D.06	Inclined Plane (Slope-Length x Width)	3% 1.40mx1.50m	

(E) ACCESS RAMPS DETAILS – RAMP #02 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	General Picnic Area	P.06.2-3
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	17% - 13.0m x 1.20m	



Picnic Area Kornos, Larnaca

LCA 021

D.08	Inclined Plane Handrails information	Both Sides	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	65cm & 95cm	
D.10	Inclined Plane - Width between Handrails	1.20m	
D.11	Inclined Plane Edge Protection	Yes	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.50m	
D.13	Bottom Landing Tactile Warning Strip	No	

ACCESS RAMPS DETAILS – RAMP #03 (≥5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.4-6
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	2	
D.04	Number of intermediate Level Landings	1	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	1 st Inclined Plane (Slope-Length x Width)	5%-10.0m x 1.20m	
D.08	1 st Inclined Plane Handrails information	Both Sides/One Side/No	
D.09	1 st Inclined PlnHandrails Height (70cm & 90cm)	70cm & 90cm	
D.10	1 st Inclined Plane - Width between Handrails	1.00m	
D.11	1 st Inclined Plane Edge Protection	Yes	
D.12	1 st intermediate Level Landing (Length x Width)	1.50m x 1.20m	
D.13	1 st Landing Handrails information	Both Sides/One Side/No	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 nd Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.00m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20	Bottom Landing Dimensions (Length x Width)	1.50m x 1.20m	
D.21	Bottom Landing Tactile Warning Strip	No	