



(A) GENERAL SITE/BUILDING INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
A.01	Number of Floors	2(underground)	P.01.1-2
A.02	Receptionist	Yes	
A.03	Qualified Singer / Languages Spoken	No	
A.04	Site Access	Vehicle/Wheel Chair	
A.05	Parking Area Access	Automated	
A.06	Drop Off Point	No	P.02
A.07	Onsite Disabled Parking Spaces (at 2 levels)	5 - (3.50X5.50m)	P.03.1-2
A.08	Onsite Wheelchair-Accessible Vehicle Parking	No	P.04
A.09	On-Street Disabled Parking (2.70x5.00m)	No	P.05
A.10	Access Ramps	Yes (More info in part D)	P.06.1-7
A.11	Lifting Platforms	No	P.07
A.12	Disabled Bathrooms- Dimensions/ Door width	Yes (2.00mx1.70m/1.00m)	P.08.1-2
A.13	Disabled Elevators	Yes (More info in part C)	P.09.1-4
.1-	Tactile Site/Building Guidance	No	
A.15	Braille Writing System Signage/Tactile Diagrams	No	
A.16	Hearing/Speech Impaired Communication Syst.	No	
A.17	Emergency Alerting Systems	No	
A.18	Staircase Disabled Emergency Waiting Point	No	
A.19	Surface Materials – Parking Area	Concrete	P.10
A.20	Surface Materials – Entrance	Concrete	P.01
A.21	Surface Materials – Reception/Lobby	N/A	P.12
A.22	Surface Materials – Corridors	N/A	P.13
A.23	Surface Materials – Other Indoor Spaces	Concrete	P.14
A.24	Surface Materials – Outdoor Gathering Spaces	N/A	P.15
A.25	Main Entry Vestibule	N/A	
A.26	Main Entry Door Operation	Auto/Open at all times	
A.27	Main Entry Door Type/ Single Door Width	N/A	
A.28	Main Entry Door Opening Direction	N/A	
A.29	Main Entry Door Threshold Height	N/A	
A.30	Interior Doors Width (min/max width)	N/A	
A.31	Corridor Width (min/max width)	N/A	
A.32	Corridor Widening Point (≥1.80x1.80m)	N/A	
A.33	Drain Covers Types	Yes (see photo)	P.16
A.34	Indoor Light Intensity(LUX)	INA	
A.35	Outdoor Light Intensity (LUX)	INA	



(B) SITE/BUILDING SPECIAL REQUIREMENTS INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
B.01	Special Category Type Building	Parking Building	
B.02	Ticket Counter Height/Knee Space (70cm/60cm)	1.07m/0cm	P.17
B.03	Ticket Counter Area (r ≥1.50m) or Dimensions	N/A	
B.04	Disabled Seats	N/A	P.18
B.05	Disabled Seats (Row Location)	N/A	
B.06	Theater Stage/Playing Field Disabled Access	N/A	
B.07	Church Iconostasi Access	N/A	
B.08	Vestibule Dimensions (L x W)	N/A	
B.09	Vestibule Interior Door Operation	N/A	
B.10	Vestibule Interior Door Type/ Single Door Width	N/A	
B.11	Vestibule Interior Door Opening Direction	N/A	
B.12	Playground Accessibility	N/A	P.19
B.13	Special Needs Playground Equipment	N/A	P.20
B.14	Inclusive Site/Building Furnishings	No	P.21
B.15.1	Other: There is a continuous ramp for 2 floors, with no landing	No	P.22.1
B.15.2	Other: There is no access from sidewalk		P.22.2-4
B.15.3	Other: Bathrooms are on the street level, on the car entry side. There is no accessibility to this point, from elevator, due to various obstacles		

(C) ELEVATOR INFORMATION			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
C.01	Elevators for Disabled	1	P.09.1-5
C.02	Floor Announcement System	Yes	
C.03	Control Panel with Tactile Numbers & Braille	Yes	
C.04	Warning Floor Strip	Yes	
C.05	Waiting Area (Door - Wall Distance) ≥150cm	Yes	
C.06	Door - Frame Color Contrast	Low	P.09.1
C.07	Door Width ≥90cm	Yes	
C.08	Elevator Cabin Dimensions ≥110 x 140cm	No (1.20mx1.30m)	
C.09	Elevator Cabin Dimensions ≥110 x 220cm	No	
C.10	Wall Mirror Inside Cabin	Yes	
C.11	Cabin Handrails	Yes	
C.12	Cabin Control Panel (Tactile Numbers/Braille)	Yes	
C.13	Cabin Announcement System	Yes (GR)	
C.14	Cabin Anti-Slip, non-Reflective Floor	Yes	
C.15	Cabin Emergency Communication System	Yes	
C.16	Waiting Area Light Intensity (200 LUX)	No	



(D) ACCESS RAMPS DETAILS – RAMP #01 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/ Outdoor	P.06.1-7
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	7	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	No	
D.07	Inclined Plane (Slope-Length x Width)	11% - (2 floors x 1.20m)	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Plane Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	N/A	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	Yes	

(D) ACCESS RAMPS DETAILS – RAMP #02 (≥ 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/ Outdoor	P.06.5-9
D.02	Rain Protection System	No	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Top Landing Tactile Warning Strip	Yes	
D.07	Inclined Plane (Slope-Length x Width)	28% - 20.0m x 1.20m	
D.08	Inclined Plane Handrails information	No	
D.09	Inclined Pln Handrails Height (70cm & 90cm)	N/A	
D.10	Inclined Plane - Width between Handrails	1.00m	
D.11	Inclined Plane Edge Protection	No	
D.12	Bottom Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.13	Bottom Landing Tactile Warning Strip	Yes	
D.14	1 st Landing Edge Protection	Yes	
D.15	2 nd Inclined Plane (Slope-Length x Width)	5% - 10.0m x 1.20m	
D.16	2 nd Inclined Plane Handrails information	Both Sides/One Side/No	
D.17	2 nd Inclined Pln Handrails Height (70cm & 90cm)	70cm & 90cm	
D.18	2 nd Inclined Plane - Width between Handrails	1.00m	
D.19	2 nd Inclined Plane Edge Protection	Yes	
D.20		1.50m x 1.20m	
D.21		No	



(D) ACCESS RAMPS DETAILS – RAMP #03 (< 5%)			
ITEM#	PROVISION DESCRIPTION	CHECKLIST	PHO#
D.01	Access Ramp Location	Entrance/Indoor/Outdoor	P.06.1-3
D.02	Rain Protection System	Yes/No/Indoor	
D.03	Number of Inclined Planes	1	
D.04	Number of intermediate Level Landings	0	
D.05	Top Landing Dimensions (Length x Width)	≥1.50m x 1.20m	
D.06	Inclined Plane (Slope-Length x Width)	4.5% - 10.0m x 1.20m	



(E) SIGNAGE INFORMATION			
ITEM#	AREA – SIGNAGE PROVISION	CHECKLIST	PHO#
E.01	Site/Building – Address Number	No	
E.02	Site/Building – Site/Building Name	No	P.01
E.03	Parking – Disabled Parking Space Symbol	Yes	P.03.1-3
E.04	Parking – International Accessibility Symbol	Yes	
E.05	Parking – Building Access Ramp Location	No	
E.06	Parking – Site Diagram	No	
E.07	Parking – Directional	No	
E.08	Parking – General Information	No	
E.09	Entrance/Reception – Site/Building Diagram	No	
E.10	Entrance/Reception – Directional	No	
E.11	Bathroom Location	Yes	
E.12	Entrance/Reception – General Information	No	
E.13	Inside Facility – Exhibition Area Labels	N/A	
E.14	Inside Facility – Site/Building Diagram	N/A	
E.15	Inside Facility – Directional	N/A	
E.16	Inside Facility – Bathroom Location	N/A	
E.17	Inside Facility – Emergency Exit	N/A	
E.18	Facility’s Outdoor Area – Site Diagram	N/A	
E.19	Facility’s Outdoor Area – Directional	N/A	
E.20	Other(Description)	No	

**(F) HEARING & SPEECH IMPAIRED INFORMATION**

ITEM#	AREA – PROVISION DESCRIPTION	CHECKLIST	PHO#
F.01	Qualified Signer	No	
F.02	Sign Languages Spoken	N/A	
F.03	Reception Design Specific Space	N/A	
F.04	Visual Emergency Alerting Systems	N/A	
F.05	Augmenting Systems – ex. Induction Loop	N/A	
F.06	Augmenting Systems –ex. Fm	N/A	
F.07	Transforming Systems – ex. Captioned Phone	No	
F.08	Transparent Masks for Covid-19	No	

(G) VISUALLY IMPAIRED INFORMATION – TACTILE GUIDANCE

ITEM#	TACTILE PROVISION (FROM – TO)	CHECKLIST	PHO#
G.01	Public Sidewalk to Parking Area	No	
G.02	Public Sidewalk to Entrance	No	
G.03	Parking Area to Entrance	N/A	
G.04	Reception to Bathrooms	No	
G.05	Reception to other Interior Areas	No	
G.06	Interior Areas to Emergency Exit	No	
G.07	Interior Areas to Outdoor Spaces	No	

(H) VISUALLY IMPAIRED INFORMATION – BRAILLE SYSTEM & TACTILE DIAGRAMS

ITEM#	BRAILLE & TACTILE DIAGRAM PROVISION	CHECKLIST	PHO#
H.01	Parking Area – Tactile Site Diagram	No	
H.02	Parking Area – General information in Braille	No	
H.03	Entrance/Reception – Tactile Site Diagram	No	
H.04	Entrance/Reception – Tactile Building Diagram	No	
H.05	Entrance/Recep. – General information in Braille	No	
H.06	Inside Facility – Room Info & Number in Braille	No	
H.07	Room Info & Number Location in Braille	No	
H.08	Outdoor Areas – Tactile Site/Building Diagram	No	
H.09	Outdoor Areas – General Information in Braille	No	



LEGEND		
ITEM#	ABBREVIATION	MEANING
01	CY	Cypriot Dialect Sign Language
02	EN	English Sign Language
03	GR	Greek Sign Language
04	TG	Tactile Guidance
05	INA	Information Not Available
06	N/A	Not Applicable
07	OSS	Out of Specifications
08	r	Radius
09	(L x W)	Length X Width
10	V	Vehicle Access
11	BF	Basement Floor
12	GF	Ground Floor
13	1 st	1 st Floor
14	2 nd	2 nd Floor
15	MF	Mezzanine Floor